

**NOTICE TO CONSUMERS**  
**of the SHENANDOAH SHORES SUBDIVISION WATERWORKS**

**IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER**

State Health Officials have advised us of a failure to perform required monitoring in accordance with the Virginia *Waterworks Regulations*.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During the March 2024 monitoring period, we did not monitor for coliform bacteria. Therefore, we cannot be sure of the quality of our drinking water during that time.

One (1) sample was required for analysis and none were analyzed.

State Health Officials believe that there is little need for concern about the safety of your water because past records show that our waterworks has had no documented problems with bacteriological contamination; however, routine sampling and examination are required to determine the quality of water delivered to our customers.

**There is nothing you need to do at this time.** We will collect a bacteriological sample as soon as we can during April 2024.

For more information, please contact:

Name: Adam Dooley

Address: 3290 Shenandoah Shores Rd, Front Royal, VA 22630

Phone Number: 540-683-1034

*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.*